QC-ABSTRACT

Name of Work:- : Additional Works to Jalahalli Govt School in ward no. 16, BBMP, Bangalore

Sl No.	Item	Quantity As Per BOQ	Required No's of tests	Actual No's of tests	Tests
1	PCC 1:3:6	5.47 Cum	1	1	Cement
					Sand, Aggregates
2	Steel	62.14 Tonne	1	1	-
3	Block 6"	1292.16 Sqm	1	1	Compressive strength
4	Block 8"	187.78 Sqm	1	1	Compressive strength
5	M20	455.87 Cum	13	20	Concrete Cube Compressive strength
6	PVC Pipe 25mm	825 Mtr	1	1	-

Cubes

0-5 m^3	1set
6-15 m^3	2set
16-30 m^3	3set
31-50 m^3	4 set

Scanned with CamScanner